



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 11/12/09

Code 19.2.3-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title IRC		Edition 2009
Section number and title R302.11.1 Fireblocking Material		Page
Proponent Jeff Washler	Title	
Address 3435 CR 52, Auburn, IN 46706		Phone 260.925.8427
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>8. Foam Plastic product tested in accordance with ASTM E 84 and ASTM E 814 (modified) and installed according to its ICC-ES Evaluation Report and Manufactures published installation Instructions.</p>		
REASON AND FISCAL IMPACT		
<p>Should be no fiscal impact as this is widely accepted across Indiana by many inspectors. Only a few inspectors (I only know of one county) do not accept foam plastic for this use. ICC has evaluated these products and accepted them, I feel that Indiana should accept all across the state as well. The argument will be made that the test was a modified test. The fire hose stream was omitted from the test. Once the fire hose hits this product, I fell the products job has been completed and it is time for the fire department to take over. Attached to this is a copy of ICC-ES Evaluation Report for DOW Chemical's Great stuff as an example.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		